

Statement G

Indented Markings

Originally Adopted October 1974

Revised September 1986

March 1992

May 2000

When pipe or tubing is marked by indentation, care should be taken to ensure that the markings do:

1. not reduce the wall thickness to less than the minimum value for the pipe.
2. not have any effect on the long-term strength of the pipe.
3. not provide leakage channels when elastomeric gasket compression fittings are used to make the joints.

Either the indented print line shall be in a color that contrasts with that of the pipe, or a separate print line shall be in a color that contrasts with the pipe.